

Source Water Assessment



We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings at Village Hall, 25 East State St. (1st and 3rd Mondays of each month at 7:00 pm) The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by Village Hall or call our water operator at (630) 897-2662. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>. To determine NORTHAURORA'S susceptibility to groundwater contamination, the following document was reviewed: a Well Site Survey, published in 1991 by the Illinois EPA. Based on the information obtained in this document, there are thirty potential sources of groundwater contamination that could pose a hazard to groundwater utilized by North Aurora's Community Water Supply. These include, a recreational facility, a fire station, two restaurant/food services, five store/sales, two hospital/clinics, one auto body facility, three below ground fuel storage tanks, four offices, two church/libraries, an auto repair facility, a vehicle sales, a printing facility, a school, a vehicle parking, one construction/demolition company, one equipment/vehicle washing facility, and a dry cleaners. In addition, information provided by the Leaking Underground Storage Tank and Remedial Project Management Sections of the Illinois EPA indicated sites with on-going remediation that might be of concern. The susceptibility determination for this community water supply is based on a number of criteria including monitoring conducted at the wells, monitoring conducted at the entry point to the distribution system, and available hydrogeologic data on the wells. **The Illinois EPA has determined that the North Aurora Community Water Supply's source water is not susceptible to contamination.** The land use within the wellhead protection area and the immediate vicinity of the wells was analyzed as part of this susceptibility determination. This land use includes residential, commercial, and agricultural properties, and open space.

2023 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

-----If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 second to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hot line or at <http://www.epa.gov/safewater/lead>

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2023	1.3	1.3	0.156	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2023	0	15	8.4	1	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

2023 Regulated Contaminants Detected

Water Quality Test Results

Definitions:

Avg:

Level 1 Assessment:

Level 2 Assessment:

Maximum Contaminant Level or MCL:

Maximum Contaminant Level Goal or MCLG:

Maximum residual disinfectant level or MRDL:

Maximum residual disinfectant level goal or MRDLG:

na:

mrem:

ppb:

ppm:

pCi/L:

Treatment Technique or TT:

The following tables contain scientific terms and measures, some of which may require explanation.

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

not applicable.

millirems per year (a measure of radiation absorbed by the body)

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (a measure of radioactivity)

A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2023	0.1	0.08 - 0.13	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	08/26/2021	0.12	0.067 - 0.12	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	08/26/2021	1.14	1.05 - 1.14	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Sodium	08/26/2021	37	26 - 37			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Zinc	08/26/2021	0.014	0.0077 - 0.014	5	5	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Naturally occurring; discharge from metal
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2023	2	0 - 1.8	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	2023	2	0 - 1.68	0	15	pCi/L	N	Erosion of natural deposits.

Water Hardness = 16 Grains Per Gallon/274 Mg/L


Triennial monitoring: The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some data, although accurate, is more than one year old.

Vulnerability Waiver Renewal

Due to favorable monitoring history, aquifer characteristics, and inventory of potential sources of contamination our water supply was issued a vulnerability Waiver renewal to reduce the amount of organic chemical monitoring conducted at a specific entry point with select wells for the period of January 1, 2020 to December 31, 2022. These include VOC's, SOC's, and Cyanide.

Questions?

For more information about this report or questions relating to your drinking water, please call: Adam Hake 331-385-6296
Visit us on the web at: www.northaurora.org



Water Department
North Aurora, Illinois 60542

PRST STD
US POSTAGE
PAID
PERMIT NO. 7
NORTH AURORA, IL
ECRWSS

**North Aurora
Water Quality
Report 2024**

*****ECRWSSDDM*****

POSTALCUSTOMER

January 1 to December 31, 2023

LEAD SERVICE LINE REPLACEMENT PLAN

North Aurora has completed the required Service Line Material Inventory. The Village has also submitted the initial Lead Service Line (LSL) Replacement Plan to the IEPA in April of 2024. The Inventory and Initial Replacement Plan can be found on the Village Website, along with a map: <https://northaurora.org/2022/09/21/lead-water-service-line-replacement-program-information/> There are still over 300 Unknown Services in the Village of North Aurora. Water Division personnel will be prioritizing the identification of these services over the next two years. Updates are due in April of 2025 & 2026, with the final LSL Replacement Plan due in April of 2027. For any questions, concerns or to provide information regarding your home to the Water Division, please contact the Village's Water Division at 630-897-8228 ext. 223 or Water Superintendent Adam Hake at 331-385-6296.

LEAD AND COPPER RULE REVISIONS

The USEPA's Lead and Copper Rule has been revised to include more stringent sample site classification as well as sample methods. The Village will be reaching out to water customers with Lead Service lines seeking assistance with sample collection and participation in this very important monitoring program.

PFAS AND UCMR5

In 2020, as part of a statewide program, the Village of North Aurora's Public Water Supply (PWS) was sampled for by IEPA Per- and Polyfluoroalkyl Substances (PFAS), which are a group of approximately 5,000 human-made chemicals that are manufactured for their oil and water-resistant properties. Since the 1940s, PFAS have been used in a wide range of consumer products and industrial processes and this has resulted in PFAS being released into the air, water and soil, which can pose risks to human health.

A total of eighteen PFAS compounds were sampled at the two entry points and NONE were detected in the Village of North Aurora's finished drinking water. The Village is conducting additional testing ahead of the upcoming UCMR5 monitoring program. For further information about PFAS please visit: www.eps.illinois.gov/topics/waterquality/pfas.html

WATER QUALITY REPORT FOR

VILLAGE OF NORTH AURORA

**NORTH AURORA, IL
0890600**

Annual Water Quality Report
for the period of January 1 to
December 31, 2023

This report is intended to provide you with important information about your drinking water and the efforts made by the NORTH AURORA water system to provide safe drinking water. **The drinking water source for NORTH AURORA is deep well ground water (St Peters Sandstone and Ironton - Galesville sandstone aquifer) that is currently supplied by six active deep wells (#4, #5, #6, #7, #8, #9) which are located on both the east and west sides of town.** For more information regarding this report contact:

**Adam Hake
(331) 385-6296**

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

IMPORTANT HEALTH INFORMATION

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

SOURCE OF DRINKING WATER

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.