


Huntington Storm Survey 11/1/2013

A NWS Storm Survey team went to the 1200 block of 7th Avenue in Huntington to survey a structure that suffered damage when a line of thunderstorms went through the area between 2:15 am and 2:45 am. The line of thunderstorms was associated with a passing cold front, and wind gusts along the front were measured at 62 mph at the Huntington Tri State Airport, and estimated to be 70 mph where the damage occurred.



A concrete block warehouse structure suffered damage along the west side when a few windows broke and a section of the lift roofed off. Due to the engineering this caused the west side of the second story wall to crumble.



Damage to the 2nd story of a concrete block warehouse structure.



Roof damage to a concrete block warehouse structure.

Severe Thunderstorm Watch number 557 was in effect from 12:47 am, and was cancelled for the Huntington area at 4:39 am. A severe thunderstorm warning was issued at 2:15 am valid through 3:15 am.