

POR FESR 2014-2020 - "Aid for energy efficiency projects for buildings in 2017"

Question CUP 15988.27102017.119000127

The application for funding presented relates to the energy upgrading of the building and the facilities used by the accommodation. Attention has been paid to heating and air conditioning systems. A home automation system has been introduced to serve the structure.

The investment presented in the notice provides for a cost of € 48.478,20 and a grant obtained of € 19.391,28. Objectives in terms of energy savings

<b>Progetto</b>	Consumi di energia primaria ante intervento (tep/anno)	Consumi di energia primaria post intervento (tep/anno)	Risparmio energetico (tep/anno)	Risparmio energetico (%)	CO <sub>2</sub> risparmiata(t)	CO <sub>2</sub> eq risparmiata (t)	NO <sub>x</sub> risparmiata (kg)	PM <sub>10</sub> risparmiata (kg)
Intervento impianto di condizionamento	7,50	5,91	1,59	21,20	3,10	3,10	0,10	0,10
Intervento Sistema di domotica	7,50	5,29	2,21	29,47	3,30	3,30	0,10	0,10
<b>Totale (&gt;10%)</b>			<b>3,80</b>	<b>50,67</b>	<b>6,40</b>	<b>6,40</b>	<b>0,20</b>	<b>0,20</b>

